DEVELOPMENT SERVICES DEPARTMENT 201 N. STONE AVE. P.O. BOX 27210 TUCSON, AZ 85726-7210 (520) 791-5550

www.tucsonaz.gov/dsd/

PETITION OF APPEAL TO THE BUILDING OFFICIAL

on this form. Supporting data may be attached and ries and statements on the form must be complete. PAGE FOR FEES & INSTRUCTIONS	DATE EMPLOYEE FAMILIAR WITH THE PROJECT	
Project Address	ACTIVITY#	
Owner's Address	Phone #	
Tenant's Address	Phone#	
Appellant's Address	Phone #	
Building Official for an alternate method/material or	interpretations of Section of	
	ts an unusual problem. (Use	
sed in lieu of literal compliance:		
	Title	
	ILATIONS	
3	Tenant's Address Appellant's Address to Project Building Official for an alternate method/material or ch requires that: nce with the above requirement on the project present posed in lieu of literal compliance: nt is not Owner Appellant DECISION OF THE BUILDING OFFICIAL	

** PETITION OF APPEAL INFORMATION PAGE **

Appeals to the Building Official -

Appeals made to the Building Official for an alternate method/material or interpretation of the City of Tucson Building Codes.

- 1. APPEAL FORM MUST BE FILLED OUT IN IT'S ENTIRETY AND FEES PAID IN ORDER TO SUBMIT. FEES FOR AN APPEAL ARE \$120.00
- 2. APPEALS WILL NOT BE ACCEPTED WITHOUT PROOF OF PAYMENT.
- 3. WE HAVE PROVIDED SEVERAL WAYS FOR YOU TO SUBMIT YOUR FORM AND PROOF OF PAYMENT:

201 N STONE AVE, 2ND FLOOR PLANNING AND DEVELOPMENT SERVICES BETWEEN THE HOURS OF 8:00 AM AND 4:00 PM M-F.

MAILED WITH COPY OF RECEIPT TO PLANNING AND DEVELOPMENT SERVICES, PO BOX 27210, TUCSON, AZ 85726-7210. ATTN: CLAUDIA BUFORD

FAXED WITH COPY OF RECEIPT TO (520) 791-4340

E MAILED WITH COPY OF RECEIPT TO Claudia.Buford@tucsonaz.gov

4. FORM WILL NOT BE CONSIDERED PROCESSED AND APPROVED WITHOUT THE SIGNATURE OF THE BUILDING OFFICIAL.

Water Heater Petition of Appeal for alternate termination of TPRV -

Appeal made to the Building Official specifically for an alternate method relating to Section 608.5 and 508.5 of the Uniform Plumbing Code as adopted by the Tucson of Tucson.

- 1. APPEAL FORM WITH STANDARD LANGUAGE ALREADY PROVIDED MUST BE FILLED OUT IN ITS ENTIRETY.
- 2. FORM WILL NOT BE CONSIDERED PROCESSED AND APPROVED WITHOUT THE SIGNATURE OF THE BUILDING INSPECTOR OR THEIR DEPARTMENT REPRESENTATIVE.
- 3. WE HAVE PROVIDED SEVERAL WAYS FOR YOU TO SUBMIT YOUR FORM

201 N STONE AVE, 1st FLOOR PLANNING AND DEVELOPMENT SERVICES BETWEEN THE HOURS OF 8:00 AM AND 4:00 PM M-F.

MAILED TO PLANNING AND DEVELOPMENT SERVICES, PO BOX 27210, TUCSON, AZ 85726-7210. ATTN: PERMIT COUNTER

FAXED TO (520) 791-4475

OR THE FORM CAN BE PROVIDED TO YOU BY THE BUILDING INSPECTOR DURING THE SCHEDULED INSPECTION.

4. THERE IS NO LONGER A FEE FOR THIS APPEAL.



PLANNING & DEVELOPMENT SERVICES DEPARTMENT 201 N STONE AV

PO BOX 27210, TUCSON AZ 85726-7210 (520) 791-5550

PETITION OF APPEAL TO THE BUILDING OFFICIAL

ACTIVITY #

** This is a legal document that MUST be detailed, accurate and complete. Supporting data may be attached and submitted if needed. **						
PROJECT NAME	PROJECT A	DDRESS	DATE			
OWNER'S NAME	OWNER'S A	ADDRESS		PHONE		
TENANT'S NAME	TENANT'S	ADDRESS		PHONE		
APPELLANT'S NAME	APPELANT	"S ADDRESS		PHONE		
APPELLANT'S RELATIONSHIP TO PROJECT						
Appeal is hereby made to the Building Official for an alternate method/material, or interpretation of, <u>Section 608.5</u> and 508.5 of the <u>Uniform Plumbing Code</u> as adopted by the City of Tucson.						
Water Heater temperature and pressure relief valve (tprv) discharge line is to be extended at a downward angle to the exterior of the building. Discharge from a relief valve into a water heater pan is prohibited.						
Explanation of why conformance with the above requirement on the project presents an unusual problem. (Use attachment if necessary) Existing water heater is located in an interior closet and away from exterior walls. There is no ready access to the outside without either trenching the floor or relocating the water heater.						
State specifically what is proposed in lieu of literal compliance:						
A tprv discharge line shall be run to a metal drip pan located under the water heater.						
Owner accepts and understands that if the water heater or tprv malfunction extensive water damage could result.						
Owners signature if appellant is other than owner			Appellant	Title		
DECISION OF THE INSPECTOR APPROVED STIPULATIONS DENIED						
DATE	DIRECTOR'S SIGNAT	TURE	20			